

FREQUENTLY ASKED QUESTIONS

RFP 2021-007

1. When was the existing septic tank installed? **1977**
2. Has the existing septic tank ever been pumped out? If so who pumped it? **Currently pumping approximately every 6 weeks Perry's Disposal is pumping it**
3. Do you have any drawings of the existing tank with dimensions? Wall thickness, depth, top size, bottom size, etc.... **Not Available**
4. Will there be water available on site for cleaning/flushing existing septic tank? **Yes outside hose bib**
5. Can we waste excess dirt on site? **Yes, will need to level off, dress down and seed and mulch**
6. The drawings show drain field lines at different lengths when (scaled) and the measurements shown do not coincide with what is scale. Should I use what is scaled per the drawings or is there a set length of drain field that needs to be installed? **Set length of 2000 feet of drain field lines per Health Department.**
7. What is the size of the existing septic that is to be relocated? **10,000 gallons**
8. Is there any information available on how the existing tank was constructed? **N/A**
9. Are we sure that the tank is constructed in a way that will withstand being moved? **To the best of our knowledge**
10. Who is responsible if tank is damaged during relocation? **Contractor**
11. Does the Garrett County Health Dept. ultimately have to approve the system? If so, have they reviewed and approved the plans? **Contractor is responsible for designing and submitting plans to the Health Department for approval.**