

**BUSHEY FEIGHT MORIN ARCHITECTS INC.**  
473 North Potomac Street  
Hagerstown, Maryland 21740

**SOUTHERN HIGH SCHOOL**  
**Façade Renovations and Repair**  
**for the**  
**GARRETT COUNTY PUBLIC SCHOOLS**

**PSC PROJECT NO. 11.005.21SR**  
**GCPS BID No. SH-20-01**  
**BFM PROJECT NO. 19071 / DP-15**

**ADDENDUM NO. 4**

April 3, 2020

TO: All prime contractors and all others to whom drawings and specifications have been issued acknowledge receipt of this Addendum by inserting its number and date of receipt on the Proposal Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents.

**GENERAL:**

ITEM NO. 4.01 For submission of electronic bids please submit your bids to the following email address. [Sh.frontfacade@garrettcountyschools.org](mailto:Sh.frontfacade@garrettcountyschools.org)

**ADDENDUMS:**

ITEM NO. 4.02 Per Addendum No. 3 – Item 3.01; The bids will be quickly reviewed, and a bid tab will be posted to the website approximately 30 minutes after the opening.

**SPECIFICATIONS:**

ITEM NO. 4.03 SECTION 08 52 00 – ALUMINUM WINDOWS; Article 1.6.J, ADD the following paragraph as follows: “Paragraph J – J. Operable windows must meet egress requirements.”

ITEM NO. 4.04 SECTION 08 80 00- GLAZING; Article 2.9.A.4: ADD “Kind HS (heat strengthened).”

**DRAWINGS:**

ITEM NO. 4.05 DRAWING A2.1 – DOOR SCHEDULE; Window Types; Revise window W1 size as follows “3’5” wide by 5’-10” high”

ITEM NO. 4.06 DRAWING A2.2 – DOOR AND WINDOW DETAILS;

A. REVISE as follows for details 5, 6, & 7: Provide window trims clips around perimeter of the window.

B. Details 6 & 7 – Note the following due to increased size of windows – Provide metal trim closure to close off gap if any between the ceiling tile grid / edge metal to the top of the window opening.

ITEM NO. 4.07 DRAWING A3.1 – BUILDING ELEVATIONS; REVISE details to indicate the new window width size. (Note overall width of the project brick shall increase to maintain

the project brick along the jamb.)

ITEM NO. 4.08 DRAWING A4.1 & A4.2 – WALL SECTIONS; REVISE as follows:

- A. ADD note to Details due to slight height increase of windows to provide metal trim to close off gap between top of the window and the ceiling as required.”

**CLARIFICATIONS:** N/A

**END OF ADDENDUM NO. 4**

**ATTACHMENTS:** N/A