

BUSHEY FEIGHT MORIN ARCHITECTS INC.
473 North Potomac Street
Hagerstown, Maryland 21740

SOUTHERN HIGH SCHOOL
Façade Renovations and Repair
for the
GARRETT COUNTY PUBLIC SCHOOLS

PSC PROJECT NO. 11.005.21SR
GCPS BID No. SH-20-01
BFM PROJECT NO. 19071 / DP-15

ADDENDUM NO. 5

April 6, 2020

TO: All prime contractors and all others to whom drawings and specifications have been issued acknowledge receipt of this Addendum by inserting its number and date of receipt on the Proposal Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents.

GENERAL: N/A

ADDENDUMS: N/A

SPECIFICATIONS:

ITEM NO. 4.01 SECTION 08 52 00 – ALUMINUM WINDOWS; REVISE as Follows:

- A. Article 2.1.A.6, ADD the following paragraph as follows: “Paragraph 6: “6. Winco Window Company.”
- B. Article 2.3.I.; ADD the following paragraph I: “I. 1 1/2” x 3”. Interior trim with continuous base at head jambs, and sill.
- C. Article 2.5.A; Revise to Read: Two white bronze sweep locks and keepers finished US26D per window.
- D. Article 2.5.C.; REVISE to Read: “Class 5” in lieu of Class II.

DRAWINGS:

ITEM NO. 4.02 DRAWING A3.1 – BUILDING ELEVATIONS; Detail 2/ A3.1 ADD to windows on second floor on each side of column line #4. Note: these are shown on plan.

CLARIFICATIONS: N/A

END OF ADDENDUM NO. 4

ATTACHMENTS: N/A